ELSEVIER

Journal of Wind Engineering
and Industrial Aerodynamics 53 (1994) 441–452

JOURNAL OF
wind engineering
AND
industrial
aerodynamics

Further experiments on Irwin's surface wind sensor

Hanqing Wu, Theodore Stathopoulos*

Centre for Building Studies, Concordia University, Montreal, Quebec, Canada H3G 1M8

Received 22 December 1992; accepted 12 October 1993

Abstract

The simple surface wind sensor proposed by Irwin measures wind speeds through pressure differences. It has been applied in several wind-tunnel laboratories for the study of pedestrian-level wind conditions. However, some characteristics related to sensor performance for wind-tunnel measurements have not been fully investigated. Discussed in this paper are: calibration of the sensor for measuring mean and rms wind speeds, the effect of sensor height on measurement errors, the interference between nearby sensors, and the response of sensors to turbulent wind conditions. Data presented here supplement Irwin's original results on the surface wind sensor and provide additional insight in the performance of the sensor.

1. Introduction

In wind-tunnel experiments for determining the pedestrian-level wind speeds it is often required to make measurements at numerous locations, for various wind directions and at a low level near the ground. Traditional measuring techniques, such as Pitot tubes and thermal anemometers, are either inaccurate or inconvenient for these measurements. Therefore, an omnidirectional pressure sensor was proposed by Irwin [1] for the measurement of surface wind flows.

Fig. 1 shows the sensor of Irwin's original design with *standard* dimensions, and the sensor fabricated at the Building Aerodynamics Laboratory of the Centre for Building Studies in Concordia University, Montreal. Each sensor consists of two brass tubes and a mounting base. One of the tubes protrudes out of the base as a probe, while the other is connected with a circular hole on the base around the probe. Pressure differences between the inlets of the two tubes are outputs of the sensor. For the two sensors shown in Fig. 1, there are some slight differences in dimensions due to the availability of materials and the convenience of fabrication. The new sensor has a variable probe height ($h = 0$ to 5 mm)

---

* Corresponding author.

SSDI 0167-6105(94)E0054-3